



**Diesel Generator
Sales, Installation,
Hire, Spares, Service
& Refurbishment**



Certificate No: 1152

USED GENERATOR SPECIFICATION SHEET PLANT No: YP341

YP Plant No:	YP341		
KVA:	1000		
Assembled by:	FG Wilson		
Year of Manufacture:	2003		
Number of Hours:	25		
Engine make:	Perkins	MODEL :	4008TAG2A
Engine serial no:	DGB082031U0052K		
Engine type:	Inline 6 cylinder turbocharged aftercooled generator		
Alternator make:	Leroy Somer	MODEL:	LL9124H
Alternator serial no	169182/01	FRAME:	Containerised
Alternator type:	Brushless	RATING :	Continuous
:	KVA	1000	PRIME
:	KW	800	PRIME
:	KVA	1100	STANDBY
:	KW	880	STANDBY
:	VOLTS	415/240	
:	CYCLES	1500	
:	AMPS	1391	
:	PHASE	3	
Control panel:	The unit is fitted with a set mounted control panel arranged for remote start operation complete with monitoring for battery volts, hours clock, water temperature, oil pressure, frequency, amps and alternator volts. Protections and automatic shutdown are provided for Low oil pressure, high engine temperature and over speed.		
General :	Ex standby unit which has only run 25 hours from new. The unit is mounted in a full acoustic container which reduces the noise level to approx 80DBA @ one meter. The unit is complete with engine heaters, fire valves, set mounted control panel and output circuit breaker. The unit is in mint condition		
PRICE:	<u>Please enquire for quotation EX-WORKS + VAT</u>		
DIMENSIONS:	9000MML X 2460MMW X 2600MMH (Plus silencer box) 16,000KGS		

THE UK'S No1 GENSET REFURBISHER

TEL : +44 1977 688155 FAX : +44 1977 688158

Registered Office:
Yorpower Limited
Unit 2 Hurricane Close
Sherburn In Elmet
LS25 6PB
UNITED KINGDOM



T: +44 (0) 1977 688155
F: +44 (0) 1977 688158
E: sales@yorpower.com
W: www.yorpower.com

Yorpower Limited, Registered in England and Wales No. 7035780