

Diesel Generator Sales, Installation, Hire, Spares, Service & Refurbishment



Certificate No: 1152

USED GENERATOR SPECIFICATION SHEET PLANT No: Y0284				
YP Plant No:	Y0284		1 EART 10: 10204	
KVA:	640			
Assembled by:	FG WILSON			
Year of Manufacture:	1985			
Number of Hours:	990			
Engine make:	PERKINS		MODEL :	CV500G
Engine serial no:	CVM12205-4			
Engine type:	12 Cylinder "V" form tubocharged water cooled diesel			
Alternator make:	Newage Stamford			
Alternator serial no	J9064/1		FRAME:	
Alternator type:	SC734B		RATING:	CONTINUOUS
:	KVA 640			PRIME
:	KW 512			PRIME
	KVA 704			STANDBY
	KW 563			STANDBY
:	VOLTS 415/240			
:	CYCLES 1500			
:	AMPS 1730			
:	PHASE 3			
Control panel:	The unit is fitted with a brand new a set mounted fully digital control panel arranged for remote start operation complete with monitoring for battery volts, hours clock, water temperature, oil pressure, frequency, amps and alternator volts. Protections and automatic shutdown are provided for Low oil pressure, high engine temperature and over speed.			
General :	The unit is ex standby with low hours and has an oversize alternator 1200KVA. Unit is open type skid mounted with brand new digital control panel.			
PRICE:	Please enquire for quotation EX-WORKS + VAT			
DIMENSIONS:	3800MML X 1560MMW X 2250MMH 6000KGS			

Registered Office: Yorpower Limited Unit 2 Hurricane Close Sherburn In Elmet LS25 6PB **UNITED KINGDOM**



T: +44 (0) 1977 688155 E: sales@yorpower.com W: www.yorpower.com

F: +44 (0) 1977 688158